

H - 7-Day Time Switch for EASY500/700 Controllers

Can be used for	
Device	From version no.:
EASY500	01
EASY700	01

General

EASY500 and EASY700 with the type reference "easy...-.C." (Clock) are equipped with a device clock (real-time clock) and allow the use of a 7-day time switch and a year time switch.

For this purpose, EASY500/700 devices offer eight time switches H1...H8 for a total of 32 switch times.

Compatibility with EASY400 and EASY600

If you wish to load an existing EASY400 or EASY600 circuit diagram, the existing 7-day time switch functions are retained. The 7-day time switch in EASY500/700 devices operates in the same way as in an EASY400/600 device.

Function

You must use a 7-day time switch in your circuit diagram exclusively as a contact. This contact will switch according to the switch times you have set.

Note: If the off time is earlier than the on time, the control relay will not switch off until the following day.

Each 7-day time switch is provided with four channels, A, B, C and D. These channels of the 7-day time switch all act jointly on the contact Hx that you include in the circuit diagram.

The following settings are possible for each channel:
Either day 1 to day 2, e.g. Monday to Friday, or only day 1.

The following abbreviations are used for the individual days of the week:
Monday = Mon, Tuesday = Tue, Wednesday = Wed, Thursday = Thur, Fri = Fri, Saturday = Sat, Sunday = Sun
The time to be entered must be between 00:00 and 23:59.

If you select the Call enabled option in the Parameter display area, you can set the channels on the device.

Behaviour in the event of a power failure

The time and date are backed up in the event of a power supply failure and continue to run. However, the time switch relays will no longer switch. The contacts are kept open when de-energized.

Switching time ranges

The following examples illustrate the function of the 7-day time switch:

[Example 1](#) : Single-channel, on successive days, on and off switching.

[Example 2](#) : Two-channel, on successive days, on and off switching.

[Example 3](#) : Two-channel, on switching on a weekday and off switching on another weekday.

[Example 4](#) : Two-channel, on and off switching on several overlapping weekdays.

[Example 5](#) : Two-channel, switch on at 0:00 on a weekday and switch off at 0:00 on another weekday.

Linking and Parameter Assignment of a 7-Day Time Switch

Requirements: You have included a control relay in the project and have switched to Circuit Diagram View.

Activating a 7-day time switch according to example 1

- ▶ Position an H 7-day time switch operand in the circuit diagram on a contact field so that you can use the switch function.
- ▶ In the Properties field window select the required function block number between 1 and 8 on the Circuit Diagram Element tab. The operand H0x will now be shown in the circuit diagram.
- ▶ If required, change the switch function of the contact from break to make contact.
- ▶ In the Parameters tab, Channel A set the weekday DY1 and at ON the hour and minute when the associated contact is to switch on.
- ▶ In the Parameters tab, Channel A set the weekday DY2 and at OFF the hour and minute when the associated contact is to switch off.
- ▶ If required, change the enable of the parameter display and/or write a comment for the selected operand.
- ▶ Connect this H0x contact in the circuit diagram.


Circuit diagram elements and parameters

	Description	Note
Contact		
Hx	Status 1 if the on condition is fulfilled.	
Coil function		
-	-	
Parameter display		
Call enabled	Function block parameters can be viewed on the device.	
Simulation		
-		

Parameter examples

Example 1: Single-channel, on successive days, on and off switching.

The 7-day time switch is required to switch from 10:00 to 18:00 from Fridays to Sundays.



Signal diagram

The H 7-day time switch must be assigned the following parameters:

Circuit Diagram Element Parameters


H: 1 Comment:

Channel A	Channel B	Channel C	Channel D
Day	Day	Day	Day
DY1: Fri	DY1: <input type="text"/>	DY1: <input type="text"/>	DY1: <input type="text"/>
DY2: Sur	DY2: <input type="text"/>	DY2: <input type="text"/>	DY2: <input type="text"/>
Hour Minute	Hour Minute	Hour Minute	Hour Minute
ON: 10 00	ON: <input type="text"/> <input type="text"/>	ON: <input type="text"/> <input type="text"/>	ON: <input type="text"/> <input type="text"/>
OFF: 18 00	OFF: <input type="text"/> <input type="text"/>	OFF: <input type="text"/> <input type="text"/>	OFF: <input type="text"/> <input type="text"/>
Parameter Set	Parameter Set	Parameter Set	Parameter Set
+ Call possible	+ Call possible	+ Call possible	+ Call possible

Entry screen in the programming software


Example 2: Two-channel, on successive days, on and off switching.

The 7-day time switch is required to switch from Mondays to Fridays between 6:30 and 9:00 and between 17:00 and 22:30.



Signal diagram


The H 7-day time switch must be assigned the following parameters:



Entry screen in the programming software


Example 3: Two-channel, on switching on a weekday and off switching on another weekday.

The 7-day time switch is required to switch on at 18:00 on Tuesdays and switch off at 6:00 on Saturdays.



Signal diagram


The H 7-day time switch must be assigned the following parameters:



Entry screen in the programming software

Example 4: Two-channel, on and off switching on several overlapping weekdays.


The 7-day time switch settings of a time switch overlap. The time switch is required to switch on at 16:00 on Mondays, and at 10:00 on Tuesdays and Wednesdays. The off time for Mondays to Wednesdays is 22:00.



Signal diagram

Note: On and off times always depend on the channel that switches first.


The H 7-day time switch must be assigned the following parameters:



Entry screen in the programming software

Example 5: Two-channel, switch on at 0:00 on a weekday and switch off on another weekday at 0:00.

The time switch should switch for 24 hours. Switch on at 0:00 on Mondays and switch off at 0:00 on Tuesdays.



Signal diagram

The H 7-day time switch must be assigned the following parameters:

The screenshot displays the 'Parameters' tab of a programming software interface. At the top, there are two tabs: 'Circuit Diagram Element' and 'Parameters'. Below the tabs, there is a field for 'H:' with a dropdown menu set to '1' and a 'Comment:' field. The main area is divided into four columns, each representing a channel (Channel A, Channel B, Channel C, and Channel D). Each channel has the following settings:

- Day:** A dropdown menu.
- DY1:** A dropdown menu.
- DY2:** A dropdown menu.
- ON:** Two dropdown menus for 'Hour' and 'Minute'.
- OFF:** Two dropdown menus for 'Hour' and 'Minute'.
- Parameter Set:** A dropdown menu with the option '+ Call possible'.

Entry screen in the programming software

Note: After power on, the control relay always updates the switch state of contact HOxx from all defined switch time entries.

DST setting

If you have activated the [DST](#) the device clock will automatically switch between summer and winter time.

Tip: Refer to the EASY500/700 manual (AWB 2528-1508x) for more information on the function block (e.g. signal diagram).